

# PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

**CERTIFICATE NO.:** CQC2016010302839973

**Valid from:** Mar.16,2021

**Valid until:** Feb.04,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** SOCOMEC China Co.,Ltd.  
Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**NAME AND LOCATION OF THE FACTORY** SOCOMEC S.A  
1, Rue De Westhouse 67230 Benfeld Cedex France

**PRODUCT NAME, MODEL AND SPECIFICATION** Fuse-switch-disconnector  
Model: FUSERBLOC 100A, FUSERBLOC 125A,FUSERBLOC 160A;Uimp:8kV;Ui:800V;Ith: 100A,125A,160A;Ue: AC415V(FUSERBLOC 160A),AC500V(FUSERBLOC 125A),AC690V(FUSERBLOC 100A, FUSERBLOC 125A);Ie: 100A,125A,160A;Iq:100kA;Utilization Category: AC-23A;Poles: 2P,3P,4P , 3P+Additional neutral pole(N) (Uninterrupted N Pole);Frequency of operating cycles : 50/60Hz

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 14048.3-2017

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.  
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



**SIGNED BY:**

**PRESIDENT:**

**CHINA QUALITY CERTIFICATION CENTRE**